

# MINIMUM REQUIREMENTS

## Kentucky Home Performance

### Kentucky Home Performance (KHP) Incentives

KHP offers incentives of 20 percent of the total installation cost for a maximum rebate of \$2,000 per home for eligible improvements.

- or -

A low-interest rate loan at 6.99 percent is also available for eligible improvements.

### Other Incentives

State and federal tax credits may apply.

Some additional local utility and manufacturer rebates may be available in your area.

### Air Sealing:

Targeted areas below are required when test-in leakage exceeds 0.40 ACHn, and may be discontinued once that threshold is met. All items should be addressed on an “as accessible” basis.

- Attic Plane, Including:
  - Interior and exterior wall top plates
  - Chases and dropped soffits
  - Chimneys and flue pipes
  - Attic accesses, doors, and pull down stairs
  - Plumbing, electrical, and duct penetrations
  - Recessed lights
- Crawlspace or Basement:
  - Chases
  - Bathtub and shower drains
  - Plumbing, electrical, and duct penetrations
  - Rim Joist
- House-to-Garage Connections—as needed and properly prioritized

### Duct Sealing:

Targeted areas below are required when test-in leakage exceeds 10 percent leakage to outside of rated fan flow and may be discontinued once that threshold is met. All items should be addressed on an “as accessible” basis.

- Holes and disconnects
- High pressure areas (returns and plenums)
- Supply take-offs
- Joints, seams, boots, and boot connections to floors, walls, and ceilings
- Insulate ducts as thoroughly as possible

### Insulation/Health and Safety:

- Ceilings/Attic: R-19; If not, then must go to R-38
- Attic Accesses: (doors, hatches, pull-down stairs) R-10 and air-sealed/gasketed
- Floor above unconditioned space: R-11; If not, then must go to R-19 (alternative: perimeter insulation R-10)
- Rim/band joists: R-10
- CO Monitor required in every house
- BPI Health and Combustion Safety Requirements